

Agrichem Analytical Drinking Water Report

409 Stewart Rd
Salt Spring Island, BC
V8K 1Y6

Phone/Fax: 250.538.1712
web: www.agrichem.ca
email: info@agrichem.ca

Salt Spring Water Co
glass carboy M+L

current treatment
unknown

sample 53108
date received 15-Jun-10
time/temperature °C
date of report 22-Jun-10
sampled by agrichem

Potable Water Quality Standards

<i>Health Canada (2008)</i>	<i>Island Trust (2001)</i>
6.5 to 8.5 *	6.5 to 8.5 *
700 **	

pH **7.25**
Conductivity **155 uS/cm**

< is "less than " > is "greater than "

* aesthetic - no health risk

** maximum

*** 20 mg/L for restricted diets

**** surface water or surface influenced groundwater (drilled well) source 1 NTU **

secure groundwater (drilled well) source 5 NTU *

the presence of Total Coliform bacteria indicates surface influenced water source

For the Total Coliforms and E. coli method, 0 is UNDETECTED and is technically < 1 MPN/100ml

This water sample meets the Health Canada Guidelines for Potability for all parameters tested.