

Agrichem Analytical Drinking Water Report

409 Stewart Rd
Salt Spring Island, BC
V8K 1Y6

Phone/Fax: 250.538.1712
web: www.agrichem.ca
email: info@agrichem.ca

Salt Spring Water Co
glass carboy

current treatment
none

sample 43917
date received 30-Apr-09
time/temperature 16:30 12 °C
date of report 04-May-09
sampled by agrichem

Potable Water Quality Standards

			<u>Health Canada (2004)</u>	<u>Island Trust (2001)</u>
<i>Total Coliforms</i>	< 1	MPN/100ml	<1	<1
<i>E. coli</i>	< 1	MPN/100ml	<1	<1

< is "less than " > is "greater than "

- * aesthetic
- ** maximum
- *** 20 mg/L for restricted diets
- **** surface water or surface influenced groundwater (drilled well) source
- secure groundwater (drilled well) source
- the presence of Total Coliform bacteria indicates surface influenced water source

This water sample meets the Health Canada guidelines for potability for all parameters tested.