

# Agrichem Analytical Drinking Water Report

409 Stewart Rd  
Salt Spring Island, BC  
V8K 1Y6

Phone/Fax: 250.538.1712  
web: www.agrichem.ca  
email: info@agrichem.ca

Salt Spring Water Co

4L glass carboy

*current treatment*

unknown

*sample* 62223  
*date received* 14-Jun-11  
*time/temperature* 14:00 10 °C  
*date of report* 15-Jun-11  
*sampled by* agrichem

*Potable Water Quality Standards*

|                        |             | <i>Health Canada (2008)</i> | <i>Island Trust (2001)</i> |
|------------------------|-------------|-----------------------------|----------------------------|
| <i>Total Coliforms</i> | 0 MPN/100ml | 0                           | 0                          |
| <i>E. coli</i>         | 0 MPN/100ml | 0                           | 0                          |

< is "less than " > is "greater than "

\* aesthetic - no health risk

\*\* maximum

\*\*\* 20 mg/L for restricted diets

\*\*\*\* surface water or surface influenced groundwater (drilled well) source 1 NTU \*\*

secure groundwater (drilled well) source 5 NTU \*

the presence of Total Coliform bacteria indicates surface influenced water source

For the Total Coliforms and E. coli method, 0 is UNDETECTED and is technically < 1 MPN/100ml

**This water sample meets the Health Canada Guidelines for Potability for all parameters tested.**