

Agrichem Analytical Drinking Water Report

409 Stewart Rd
Salt Spring Island, BC
V8K 1Y6

Phone/Fax: 250.538.1712
web: www.agrichem.ca
email: info@agrichem.ca

Salt Spring Water Co
4L glass carboy

current treatment
treated

sample 63421
date received 18-Oct-11
time/temperature 13:50 10 °C
date of report 19-Oct-11
sampled by agrichem

Potable Water Quality Standards

	<u>Health Canada (2008)</u>	<u>Island Trust (2001)</u>	
<i>Total Coliforms</i>	0 MPN/100ml	0	0
<i>E. coli</i>	0 MPN/100ml	0	0

< is "less than " > is "greater than "

* aesthetic - no health risk

** maximum

*** 20 mg/L for restricted diets

**** surface water or surface influenced groundwater (drilled well) source 1 NTU **

secure groundwater (drilled well) source 5 NTU *

the presence of Total Coliform bacteria indicates surface influenced water source

For the Total Coliforms and E. coli method, 0 is UNDETECTED and is technically < 1 MPN/100ml

This water sample meets the Health Canada Guidelines for Potability for all parameters tested.